

GFTP RECESSED TRACK INSTALLATION INSTRUCTIONS

IMPORTANT SAFETY INSTRUCTIONS

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.

- Risk of fire or electric shock.
- Disconnect all power before installing or servicing.
- Installation Instructions for qualified electricians only.
- Install per National Electrical Code and local regulations.
- Read Installation Instructions completely before installation.

INSTRUCTIONS

1. Install blocking along the path of the track layout.
NOTE: Allow for the depth of the FTP jacket (1.5").
2. Fasten the jacket to the blocking using the appropriate hardware every 4 feet. The fasteners should be mounted flush with the inner housing to allow for flush track installation.
3. Insert track into the GFTP housing and fasten every 4 feet.

